

**Public Health Engineering Department District Water-
Testing Laboratory Gwalior**

Test Report


Type of sample: Water Sample		Particular of sample : collected / not collected by PHED	
Particular of sender: Principal India International Public School Aroa Tiraha Dabra Gwalior (M.P.)			
Sample No.	Place of Collection and Details of Sample	Date of collection	
1	Water Sample	08.04.2024	
2	-	-	
3	-	-	
4	-	-	
Particular of Sample :			
Date of Receipt: 08.04.2024		Time of Receipt: 12:40 PM	
Lab Reference No:		Date of Analysis: 09-04-2024	

Nature of Study – Chemical and Bacteriological Analysis

S.N.	Characteristics	Unit	As Per BIS-10600-2012 For Drinking Water		RESULT			
			Acceptable Value	Permissible limit in the absence of alternate source	Sample 1	Sample 2	Sample 3	Sample 4
PHYSICAL TESTE								
1	Turbidity	NTU	1.0	5.0	1.8	-	-	-
2	Color	Cobalt	5	15	-	-	-	-
3	Taste & Odour		Unobjectionable	Objectionable	Unobjectionable	-	-	-
4	Temperature	C°	-	-	-	-	-	-
CHEMICAL TESTE								
5	PH Value	PH Scale	6.5 To 8.5	No Relaxation	7.0	-	-	-
6	Alkalinity	Mg/L	200	600	218	-	-	-
7	Chlorides (as Cl)	Mg/L	250	1000	32	-	-	-
8	Nitrate as No3	Mg/L	45	45	6	-	-	-
9	Total hardness	Mg/L	200	600	178	-	-	-
10	Calcium as Ca	Mg/L	75	200	28	-	-	-
11	Magnesium as mg	Mg/L	30	100	25	-	-	-
12	Iron	Mg/L	0.3	1.0	0.3	-	-	-
13	Free Chlorine	Mg/L	0.2	1.0	-	-	-	-
14	T.D.S.	Mg/L	500	2000	319	-	-	-
15	Fluoride	Mg/L	1.0	1.5	0.40	-	-	-
16	Sulphate as SO4	Mg/L	200	400	-	-	-	-
BECT. FEACAL TESTE								
17	MPN of coliform	per 100 ml	Nil		Nil	-	-	-
18	Faecal Coliform	Per 100 ml	Nil		Nil	-	-	-

This report should not be provided partially or fully without approval of signatory authorities for legal purposes.

- It is Recommended that acceptable limit is to be implemented values in excess those mentioned under "Acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source, but up to the limits indicated under the "permissible limit in the absence of alternate Source"
- The results refer only to tested samples and parameters tested.
- samples will be stored for a period of 10 days from the date of issue of report.
- This Lab does not hold any responsibility for variation in results for samples kept on hold for want of clarification.


Signature of Analyst
District Lab Gwalior


Lab In Charge
P.H.E.D. Division Gwalior (M.P.)

No. 241 /PHED/ Date :- 12/04/2024